



TGA Licence No:
MI-15112007-LI-002191-11

APVMA Licence No:
6139

AS/NZS 4020:2005 Compliance Testing

AS/NZS 4020:2005 Compliance Testing

Certificate of Conformance

(Summary of Certificate of Analysis)

Dated: 11/06/2015


The product, **Owens Corning Asphalt Shingles; Oakridge Pro 30 & Duration Premium 50yr;** was supplied by **South Pacific Shingles (2003) Ltd. (21b Gabador Pl, Mt Wellington, Auckland, New Zealand)** on **17/03/2015** for compliance testing to AS/NZS 4020:2005, Testing of products for use in contact with drinking water. All tests were completed and evaluated on **09/06/2015**.

Certificate of Analysis Reference No¹. **1506001**, is a detailed report on all tests conducted on samples of this product.

Testing although determined by the relevant product Standard, is generally recognised for up to 5 years by the certifying body, providing the testing procedures remain the same and the background information on the product is adequately documented. Also, the results stated in the report relate to the samples of the product submitted for testing. Any changes in the material formulation and supplier/manufacturer of all ingredients, the process of manufacture, the method of application, or the surface area-to-volume ratio in the end-use, could affect the suitability of the product for use in contact with drinking water, and re-testing may be required before this actual time frame, governed by the completion and evaluation date.

Based on completion and evaluation of all tests on **09/06/2015**, the product, **Owens Corning Asphalt Shingles; Oakridge Pro 30 & Duration Premium 50yr;** **fully complied with the test requirements of AS/NZS 4020:2005 to cover a cold water application up to <40°C at the recommended 'total immersion' exposure of ~14,151mm² (per product) / L test water at (20 ± 2)° C.**

Signed: _____



SANDHYA L. SINGH B. Tech, Postgrad. Dip. (Chem)
Manager, Chemistry and Toxicology; Approved Signatory

Date: 11/06/2015

¹ NOTE: For product Certification, the Certificate of Conformance must be distributed with the relevant Certificate of Analysis and Attachments.

THIS REPORT MUST NOT BE REPRODUCED EXCEPT IN FULL

Page 1 of 1

SYDNEY A 8 Rachael Close, Silverwater NSW 2128 P +61 2 9704 2300 F +61 2 9737 9425

BRISBANE A 2/120 Bluestone Circuit, Seventeen Mile Rocks QLD 4073 P +61 7 3295 0550 F +61 7 3295 0555

• TGA Licensed • APVMA Licensed • FDA Registered • NATA Accredited • ISO 17025 Quality System • Physical Containment Level 2 Laboratory

For the detailed scope of NATA accreditation, please visit www.amslabs.com.au