



CERTIFICATE OF CONFORMITY

This is to certify that

SPS Roofing and Building Materials Ltd
Owens Corning Asphalt Roofing Shingles
OAKRIDGE PRO 30, OAKRIDGE PRO 30 SUPER
BERKSHIRE AND DURATION PREMIUM



Product Description

Owens Corning Asphalt Roofing Shingles are a glass-fibre reinforced asphalt shingles surfaced with a ceramic coated mineral chip to provide protection from UV rays. The shingles, flashings and accessories form a weather tight roofing system when installed over a plywood or reconstituted wood board substrate and roofing underlay.

Complies with the New Zealand Building Code:

1. B1.3.1, B1.3.2, B1.3.3 and B1.3.4.
2. B2.3.1 (b) and B2.3.2.
3. E2.3.1, E2.3.2 and E2.3.7 (c).
4. F2.3.1.
5. G12.3.1.

Product Purpose or Use

Owens Corning Laminated Asphalt Shingles can be used as a roof cladding for buildings within the following scope:

- The scope limitations of NZBC Acceptable Solution E2/AS1 Paragraph 1.1, with regard to floor plan area and building height;
- Constructed with timber roof framing and plywood/sarking complying with the NZBC;
- Where the roof pitch is 9.5 deg or greater up to 60 deg; or
- Is located in NZS 3604:2011 Wind Zones up to and including Very High, or Extra High for Duration.

Certificate Holder

SPS Roofing and Building Supplies
72 Ellice Road, Glenfield
Auckland, 1309, New Zealand
Ph: +6421573224
W: www.spsbuilding.co.nz

Subject to the following Conditions & Limitations:

- a. Must be installed in accordance with the SPS Owens Corning Laminated Shingles Installation Instructions (version 1.0 dated 1st December 2016).
- b. The system must be installed in accordance with the technical information by a SPS Building Trained Licensed Building Practitioner and Approved Installer.
- c. The certificate holder must maintain compliance with the conditions set out in Section 15 of the Building (Product Certification) Regulations 2008.
- d. The use of reconstituted wood board sarking is conditional on a current BRANZ Appraisal Certificate confirming it is fit for purpose

Certification Body

CertMark International Pty Ltd
ABN: 80 111 217 568
JAS-ANZ Accreditation No. Z4450210AK
PO Box 321 Tuakau 2121
+64 (09) 951 8246
www.CertMark.org


John Thorpe
CertMark International Pty Ltd

31/01/2017
Date of Issue

CMA-CM40202
Certificate Number

- This certificate is issued by an independent certification body accredited by the product certification accreditation body appointed by the Chief Executive of the Ministry of Business, Innovation & Employment (MBIE) under the Building Act 2004. MBIE does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificate conforms to the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. MBIE disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate
- It is advised to check that this Certificate of Conformity is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the MBIE website, www.mbie.govt.nz
- This certificate may only be reproduced in its entirety.



WWW.JAS-ANZ.ORG/REGISTER